

HVAC Filter Replacement

Cornerstone Elementary		
Room #	Filter Rating	Filter Replacement Date
K1	Merv 10	December 16, 2020
K2	Merv 10	December 16, 2020
3	Merv 10	February 10, 2021
4	Merv 10	February 10, 2021
5	Merv 10	February 10, 2021
6	Merv 10	December 16, 2020
7	Merv 10	February 10, 2021
8	Merv 10	February 10, 2021
9	Merv 10	December 16, 2020
10	Merv 10	December 16, 2020
11	Merv 10	February 10, 2021
12	Merv 10	February 10, 2021
13	Merv 10	December 16, 2020
14	Merv 10	December 16, 2020
15	Merv 10	December 16, 2020
16	Merv 10	February 10, 2021
17	Merv 10	February 10, 2021
18	Merv 10	February 10, 2021
19	Merv 10	February 10, 2021
20	Merv 10	February 10, 2021
21	Merv 10	February 10, 2021
22	Merv 10	February 10, 2021

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Dapplegray Elementary		
Room #	Filter Rating	Filter Replacement Date
1	Merv 10	December 16, 2020
2	Merv 10	December 16, 2020
3	Merv 10	December 16, 2020
4	Merv 10	December 16, 2020
5	Merv 10	December 16, 2020
6	Merv 10	February 16, 2021
7	Merv 10	February 16, 2021
8	Merv 10	February 16, 2021
9	Merv 10	December 16, 2020
10	Merv 10	December 16, 2020
11	Merv 10	December 16, 2020
12	Merv 10	December 16, 2020
13	Merv 10	December 16, 2020
14	Merv 10	December 16, 2020
15	Merv 10	December 16, 2020
16	Merv 10	December 16, 2020
17	Merv 10	February 16, 2021
18	Merv 10	February 16, 2021
19	Merv 10	February 16, 2021
20	Merv 10	December 16, 2020
21	Merv 10	February 16, 2021
22	Merv 10	February 16, 2021
23	Merv 10	February 16, 2021
14	Merv 10	February 16, 2021
25	Merv 10	February 16, 2021
26	Merv 10	February 16, 2021
27	Merv 10	February 16, 2021
28	Merv 10	February 16, 2021
29	Merv 10	February 16, 2021
30	Merv 10	February 16, 2021

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Lunada Bay Elementary		
Room #	Filter Rating	Filter Replacement Date
1	Merv 10	June 29, 2020
2	Merv 10	June 29, 2020
3	Merv 10	June 29, 2020
4	Merv 10	June 29, 2020
5	Merv 10	June 29, 2020
6	Merv 10	June 29, 2020
7	Merv 10	June 29, 2020
8	Merv 10	June 29, 2020
9	Merv 10	February 10, 2021
10	Merv 10	February 10, 2021
11	Merv 10	June 29, 2020
12	Merv 10	June 29, 2020
13	Merv 10	June 29, 2020
14	Merv 10	June 29, 2020
15	Merv 10	June 29, 2020
16	Merv 10	June 29, 2020
17	Merv 10	June 29, 2020
18	Merv 10	June 29, 2020
19 - Library	Merv 10	June 29, 2020
20	Merv 10	June 29, 2020
K1	Merv 10	June 29, 2020
K2	Merv 10	June 29, 2020

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Mira Catalina Elementary		
Room #	Filter Rating	Filter Replacement Date
1	Merv 10	December 17, 2020
2 - Library	Merv 10	February 11, 2021
3	Merv 10	December 17, 2020
4	Merv 10	February 11, 2021
5	Merv 10	February 11, 2021
6	Merv 10	December 17, 2020
7	Merv 10	February 11, 2021
8	Merv 10	February 11, 2021
9	Merv 10	December 17, 2020
10	Merv 10	December 17, 2020
11	Merv 10	February 11, 2021
12	Merv 10	February 11, 2021
13	Merv 10	December 17, 2020
14	Merv 10	February 11, 2021
15	Merv 10	February 11, 2021
16	Merv 10	February 11, 2021
17 - Kids Corner	Merv 10	February 11, 2021
18	Merv 10	February 11, 2021
19	Merv 10	February 11, 2021
K1	Merv 10	December 17, 2020
K2	Merv 10	December 17, 2020

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Montemalaga Elementary		
Room #	Filter Rating	Filter Replacement Date
1	Merv 10	February 25, 2021
2	Merv 10	February 25, 2021
3	Merv 10	February 25, 2021
4	Merv 10	February 25, 2021
5	Merv 10	February 24, 2021
6	Merv 10	February 24, 2021
7	Merv 10	February 24, 2021
8	Merv 10	February 24, 2021
9	Merv 10	February 10, 2021
10	Merv 10	February 24, 2021
11	Merv 10	February 10, 2021
12	Merv 10	February 24, 2021
13	Merv 10	February 24, 2021
14	Merv 10	February 24, 2021
15	Merv 10	February 10, 2021
16	Merv 10	February 10, 2021
17	Merv 10	February 10, 2021
18	Merv 10	February 24, 2021
K1	Merv 10	December 17, 2020
K2	Merv 10	December 17, 2020

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Point Vicente Elementary		
Room #	Filter Rating	Filter Replacement Date
K1	Merv 10	June 22, 2020
K2	Merv 10	June 22, 2020
3	Merv 10	June 22, 2020
4	Merv 10	June 22, 2020
5	Merv 13	February 25, 2021
6	Merv 13	February 25, 2021
7	Merv 10	June 22, 2020
8	Merv 10	June 22, 2020
9	Merv 13	February 25, 2021
10	Merv 13	February 25, 2021
11	Merv 10	February 10, 2021
12	Merv 10	February 20, 2021
13	Merv 10	February 10, 2021
14	Merv 13	February 10, 2021
15	Merv 13	February 25, 2021
16	Merv 13	February 25, 2021
17	Merv 10	February 25, 2021
18	Merv 10	June 22, 2020
19	Merv 10	June 22, 2020
20	Merv 10	June 22, 2020
21	Merv 10	February 25, 2021
22	Merv 10	February 25, 2021

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Rancho Vista Elementary		
Room #	Filter Rating	Filter Replacement Date
1	Merv 10	June 18, 2020
2	Merv 10	June 18, 2020
3	Merv 10	June 18, 2020
4	Merv 10	June 18, 2020
5	Merv 10	February 12, 2021
6	Merv 10	February 12, 2021
7	Merv 10	June 18, 2020
8	Merv 10	June 18, 2020
9	Merv 10	June 18, 2020
10	Merv 10	June 18, 2020
11	Merv 10	June 18, 2020
12	Merv 10	June 18, 2020
13	Merv 10	June 18, 2020
14	Merv 10	June 18, 2020
15	Merv 10	June 18, 2020
16	Merv 10	June 18, 2020
17	Merv 10	June 18, 2020
18	Merv 10	June 18, 2020
19	Merv 10	June 18, 2020
20	Merv 10	June 18, 2020
21	Merv 10	June 18, 2020
22	Merv 10	June 18, 2020
23	Merv 10	June 18, 2020
25	Merv 10	December 18, 2020
26	Merv 10	December 18, 2020
27	Merv 10	December 18, 2020
28	Merv 10	December 18, 2020
29	Merv 10	December 18, 2020
Office	Merv 10	June 18, 2020
MPR	Merv 10	June 18, 2020

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Silver Spur Elementary		
Room #	Filter Rating	Filter Replacement Date
1	Merv 10	December 18, 2020
2	Merv 10	December 18, 2020
3	Merv 10	December 18, 2020
4	Merv 10	December 18, 2020
5	Merv 10	December 18, 2020
6	Merv 10	December 18, 2020
7	Merv 10	December 18, 2020
8	Merv 10	December 18, 2020
9	Merv 10	December 18, 2020
10	Merv 10	December 18, 2020
11	Merv 10	December 18, 2020
12	Merv 10	December 18, 2020
13	Merv 10	December 18, 2020
14	Merv 10	December 18, 2020
15	Merv 10	February 16, 2021
16	Merv 10	February 16, 2021
17	Merv 10	February 16, 2021
18	Merv 10	December 18, 2020
19	Merv 10	December 18, 2020
20	Merv 10	December 18, 2020
21	Merv 10	December 18, 2020
22	Merv 10	December 18, 2020
30-Kids Corner	Merv 10	December 18, 2020
32-Kids Corner	Merv 10	December 18, 2020
35- Kids Corner	Merv 10	December 18, 2020

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Soleado Elementary		
Room #	Filter Rating	Filter Replacement Date
C1	Merv 10	December 15, 2020
C2	Merv 10	December 15, 2020
C3	Merv 10	December 15, 2020
C4	Merv 10	December 15, 2020
C5	Merv 10	December 15, 2020
M1	Merv 10	February 10, 2021
M2	Merv 10	February 10, 2021
M3	Merv 10	February 10, 2021
M4	Merv 10	February 10, 2021
M5	Merv 10	December 15, 2020
N1	Merv 10	December 15, 2020
N2	Merv 10	December 15, 2020
N3	Merv 10	December 15, 2020
N4	Merv 10	December 15, 2020
N5	Merv 10	December 15, 2020
V1	Merv 10	February 10, 2021
V2	Merv 10	February 10, 2021
V3	Merv 10	February 10, 2021
V4	Merv 10	February 10, 2021
V5	Merv 10	February 10, 2021
P1 - Library	Merv 10	February 10, 2021
P2	Merv 10	February 10, 2021
Kids Corner 1	Merv 10	February 10, 2021
Kids Corner 2	Merv 10	February 10, 2021

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Vista Grande Elementary		
Room #	Filter Rating	Filter Replacement Date
1	Merv 10	February 24, 2021
2	Merv 10	February 24, 2021
3	Merv 10	July 22, 2020
4	Merv 10	February 24, 2021
5	Merv 13	December 17, 2025
6	Merv 13	February 26, 2021
7	Merv 10	February 10, 2021
8	Merv 10	February 10, 2021
9	Merv 10	July 22, 2020
10	Merv 13	February 26, 2021
11	Merv 13	February 26, 2021
12	Merv 13	February 26, 2021
13	Merv 13	February 26, 2021
14	Merv 10	July 22, 2020
15	Merv 13	February 26, 2021
16	Merv 13	February 26, 2021
17	Merv 10	July 22, 2020
18	Merv 10	July 22, 2020
19	Merv 10	July 22, 2020
20	Merv 10	July 22, 2020
21	Merv 10	
22	Merv 10	July 22, 2020
23	Merv 10	July 22, 2020
Kids Corner 1	Merv 10	February 26, 2021
Kids Corner 2	Merv 10	February 24, 2021

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

VELA		
Room #	Filter Rating	Filter Replacement Date
1	Merv 10	July 24, 2020
2	Merv 10	July 24, 2020
K3	Merv 13	February 25, 2021
K4	Merv 13	February 25, 2021
K5	Merv 13	February 25, 2021
K6	Merv 13	February 25, 2021
K7	Merv 10	February 25, 2021
8	Merv 10	July 24, 2020
9	Merv 13	February 25, 2021
10	Merv 13	February 23, 2021
11	Merv 10	February 23, 2021
12	Merv 10	February 23, 2021
13	Merv 10	February 22, 2021
14	Merv 10	February 22, 2021
15	Merv 10	July 24, 2020
16	Merv 10	July 24, 2020
17	Merv 10	July 24, 2020
18	Merv 10	July 24, 2020

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

MELA		
Room #	Filter Rating	Filter Replacement Date
1	Merv 10	June 24, 2020
2	Merv 10	June 24, 2020
3	Merv 10	June 24, 2020
4	Merv 10	June 24, 2020
5	Merv 10	June 24, 2020
6	Merv 10	June 24, 2020
7	Merv 10	June 24, 2020
8	Merv 10	June 24, 2020
9	Merv 10	June 24, 2020
10	Merv 10	June 24, 2020
11	Merv 10	June 24, 2020
12	Merv 10	June 24, 2020
Office 1	Merv 10	June 24, 2020
Office 2	Merv 10	June 24, 2020
MPR	Merv 10	June 24, 2020

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Miraleste Intermediate		
Building	Filter Rating	Filter Replacement Date
Band	Merv 10	June 3, 2020
Drama 1	Merv 10	June 3, 2020
Drama 2	Merv 10	June 3, 2020
Café Office	Merv 10	June 3, 2020
Cafeteria	Merv 10	March 17, 2021
Cafeteria	Merv 10	June 3, 2020
Faculty Work Room	Merv 10	June 3, 2020
Faculty Work Room	Merv 10	June 3, 2020
Main Office	Merv 10	June 3, 2020
Library 1	Merv 10	June 3, 2020
Library 2	Merv 10	June 3, 2020
102-108	Merv 10	March 17, 2021
307	Merv 10	June 3, 2020
301-313	Merv 10	June 3, 2020
401-416	Merv 10	June 3, 2020
501-507	Merv 10	March 17, 2021
607	Merv 10	June 3, 2020
601-614	Merv 10	June 3, 2020
Boys Locker	Merv 10	June 3, 2020
Girls Locker	Merv 10	June 3, 2020
Dance Room	Merv 10	March 17, 2021
Dance Room	Merv 10	March 17, 2021
Gym 1	Merv 10	March 17, 2021
Gym 2	Merv 10	March 17, 2021

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.

HVAC Filter Replacement

Ridgecrest Intermediate		
Building	Filter Rating	Filter Replacement Date
101/102	Merv 13	February 24, 2021
200	Merv 10	February 24, 2021
300	Merv 10	June 24, 2020
400	Merv 10	June 24, 2020
500	Merv 10	June 24, 2020
601-604	Merv 13	March 5, 2021
505	Merv 13	February 24, 2021
305	Merv 13	March 5, 2021
Office	Merv 10	March 5, 2021
Kitchen	Merv 10	March 5, 2021

Please note, due to the increase in demand and production of Merv 13 filters, our order is pending delivery.